



PRELIMINARY ASBESTOS SURVEY

Parcel No. 9037490
 ROW Job No. R-99-018-90
 Route FAP 331 (Ill. 13)
 Section 6-4
 County Williamson
 Location 1200 Aurelia Drive
Marion, IL

FACILITY Yes
 FURTHER ACTION RECOMMENDED:
Bulk Sampling Asphalt Roof
Bulk Sampling Vinyl Sheet Flooring
 FRIABLE ACM SUSPECTED: No
 NON-FRIABLE ACM SUSPECTED: Yes
 PROPOSED DATE OF LETTING: 01/14/94

REMARKS: The subject property is improved with a single family residence (Building #1) and a storage shed (Building #2). The residence (built in 1974) is a one and a half story brick structure containing approximately 2,335 sq. ft. of living area. Visual inspection of the exterior and interior revealed five areas of possible suspected non-friable ACM, that being the aged one layer asphalt shingled roof (containing greater than 160 sq. ft.) vinyl sheet flooring in four locations; kitchen/utility room, 1/2 bath on the lower level, full bath off the master bedroom and full bath upstairs (all areas combined being greater than 160 sq. ft.). No visual signs of friable ACM were found in the residence. The 11'x24' wood frame shed has vinyl siding and an asphalt shingled roof. Visual inspection of the interior and exterior revealed one area of possible non-friable ACM, that being the aged asphalt shingled roof (containing greater than 160 sq. ft.). No visual signs of friable ACM was found in the shed.



Inspected By: DOUGLAS J. KEIM

Date: May 12, 1993

Douglas J. Keim